



# 2025-2026 Statement of Assurance (SOA) for Testing and Reporting of Lead in School Drinking Water

**Entity Type:**

District (Incl. ESC and Jointure Commission) ⌵

**County:**

WARREN ⌵

**Entity**

Alpha Borough School District (0070) ⌵

**School Address**

817 North Blvd Phillipsburg NJ 08865

**Do you qualify for an exemption under N.J.A.C. 6A:26-12.4?**

**Answer Yes only if all of the following are true:**

- 1) Students or staff do not have access to any drinking water outlets connected to plumbing in any school facility;
- 2) The entity did not test for lead in drinking water from any outlet during the required testing year of 2024–2025; and
- 3) The entity received an exemption letter from the NJDOE.

If any of the above are not true, answer **No**.

NO ⌵

**When was the most recent lead in school drinking water testing completed?**

Jun 11, 2025

**The number of facilities in which at least one drinking water outlet was sampled:**

1

**How many drinking water outlets in total were tested?**

10

**Website of posted test results: <http://www.address:>**

<https://apsedu.org/wp-content/uploads/2025/07/Testing-of-Lead-in-School-Drinking-Water-2025.pdf>

Did any result from the latest sampling—including the first-flush sample—exceed the lead action level of 15 µg/L (15 ppb / 0.015 mg/L)?

NO

The district or school entity confirms that lead drinking water sampling and analysis were completed at all drinking water outlets, in accordance with N.J.A.C. 6A:26-12.4.

Yes

For any drinking water test result above the lead action level, the district or school entity confirms that written notifications were provided to all parents and staff, and that use of the drinking water outlet was discontinued, as required by N.J.A.C. 6A:26-12.4(e)2.

Yes

If any drinking water outlet remains closed, unavailable, or exempt, the district or school entity confirms that alternate drinking water is provided to students and staff.

Yes

The district or school entity affirms that it will continue to maintain compliance with all applicable lead testing, remediation, recordkeeping, and reporting requirements.

Yes

**Representative Title:**

Building & Grounds Supervisor

**Representative Name:**

Reinhard Sorge

**Representative E-mail:**

esorge@apsedu.org

Submission Date: 6/22/2026

**[DOWNLOAD PDF COPY NOW!](#)**

[Click here to submit the application.](#)

**WARNING:** Please do not exit or leave the page while submitting. Data entries are not saved if the page is closed before clicking the submit button.